

BCT T3000 戶外型溫溼度通訊協定

Mosbus RTU Address

Address	Code	Word	Function	Range
0000H	03H	1	Temperature	-400~1328 (-40.0~132.8℃)=FE70H~0530H
0001H	03H	1	Humidity	0~1000 (0~100.0%)=0000H~03E8H
0002H	03/06H	1	Temperature adjustment	-100~100 (-10.0~10.0℃)=009CH~0064CH
0003H	03/06H	1	Humidity adjustment	-100~100 (-10.0~10.0℃)=009CH~0064CH
0004H	03/06H	1	Sampling time	10~100 (1.0~10.0秒)=000AH~0064H